





Test Report issued under the responsibility of:



| | |
|--|---|
| TEST REPORT IEC 60947-3 Low-voltage switchgear and controlgear Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units | |
| Report Number | SGP-11242/smart ARS 2 pro/800V/CB |
| Date of issue | 24.04.2019 |
| Total number of pages | 59 pages |
| Name of Testing Laboratory preparing the Report | AIT Austrian Institute of Technology GmbH |
| Applicant's name | APATOR S.A. |
| Address | 87-100 Toruń, Gdańska nr 4a lok. C4, POLAND |
| Test specification: | |
| Standard | IEC 60947-3:2008, AMD1:2012, AMD2:2015 in conjunction with IEC 60947-1:2007, AMD1:2010, AMD2:2014 |
| Test procedure | CB-Scheme |
| Non-standard test method | N/A |
| Test Report Form No. | IEC60947_3E |
| Test Report Form(s) Originator | OVE |
| Master TRF | Dated 2017-07 |
| Copyright © 2017 Worldwide System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved. | |
| This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context. | |
| If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed. | |
| This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02. | |
| General disclaimer: | |
| The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report. | |

| | | |
|---|---|---|
| Test item description | Low-voltage fuse-switch-disconnectors | |
| Trade Mark |  | |
| Manufacturer | APATOR S.A. 87-100 Toruń, Gdańska nr 4a lok. C4, POLAND | |
| Model/Type reference | smart ARS 2-6-M PRO-PV (three pole operated) smart ARS 2-6-V PRO-PV (three pole operated) smart ARS 2-6-2V PRO-PV (three pole operated) | |
| Ratings | 800V a.c. / 200A / 50-60Hz / 3-pole | |
| Responsible Testing Laboratory (as applicable), testing procedure and testing location(s): | | |
| <input checked="" type="checkbox"/> | CB Testing Laboratory: | AIT Austrian Institute of Technology GmbH |
| | Testing location/ address | A-1210 Vienna, Giefinggasse 2, AUSTRIA |
| | |   |
| | Tested by (name, function, signature) | H. Raheb, MSc  |
| | Approved by (name, function, signature) .. | DI G. Brauner  |
| <input type="checkbox"/> | Testing procedure: CTF Stage 1: | |
| | Testing location/ address | |
| | Tested by (name, function, signature) | |
| | Approved by (name, function, signature) .. | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 2: | |
| | Testing location/ address | |
| | Tested by (name + signature) | |
| | Witnessed by (name, function, signature) . : | |
| | Approved by (name, function, signature) .. : | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 3: | |
| <input type="checkbox"/> | Testing procedure: CTF Stage 4: | |
| | Testing location/ address | |
| | Tested by (name, function, signature) | |
| | Witnessed by (name, function, signature) . : | |
| | Approved by (name, function, signature) .. : | |
| | Supervised by (name, function, signature) : | |

List of Attachments (including a total number of pages in each attachment):**Summary of testing:**

| | | Type + Sample No. | | |
|------------------------------------|------------------------------|--------------------------|------------------------|-------------------------|
| | | smart ARS 2-6-M PRO-PV | smart ARS 2-6-V PRO-PV | smart ARS 2-6-2V PRO-PV |
| Constructional Requirements | | --- | CR1 | --- |
| TSQ I | Temperature-rise | TR2M | TR2V | TR22V |
| | Dielectric properties | | | |
| | Making and breaking | 4-5 | --- | --- |
| TSQ II | | 6 | --- | --- |
| TSQ III | | --- | --- | --- |
| TSQ IV | | 16-17 | --- | --- |
| TSQ V | | TR2M | --- | --- |

Test performed:

A type test was performed according to

- IEC 60947-1 Ed. 5.2:2014
- IEC 60947-3 Ed. 3.2:2015.

The low-voltage fuse-switch-disconnectors

smart ARS 2-6-. PRO-PV

have passed the type test successfully.

Testing location:

AIT Austrian Institute of Technology GmbH
Giefinggasse 2
1210 Vienna
AUSTRIA

The AIT Austrian Institute of Technology GmbH is a recognized CB Testing Laboratory under the responsibility of OVE as the National Certification Body.



Summary of compliance with National Differences (List of countries addressed):

-

Summary of variants:










| Designation | Description |
|----------------------|--|
| smart ARS 2-6-M PRO | Fuse-switch-disconnector for busbar system 185 mm mounting, 3 pole operated <ul style="list-style-type: none"> ▪ screw terminals M12 (outgoing): Max. cross-section 240 mm² Min. cross-section 35mm² Rated torque 56Nm ▪ screw terminals M12 (busbars): Max. cross-section 100 x 10 mm² Min. cross-section 40 x 5 mm² Rated torque 56Nm |
| smart ARS 2-6-V PRO | Fuse-switch-disconnector for busbar system 185 mm mounting, 3 pole operated <ul style="list-style-type: none"> ▪ single V-shape terminals (outgoing): Max. cross-section 240 mm² Min. cross-section 50 mm² Rated torque 30 Nm ▪ screw terminals M12 (busbars): Max. cross-section 100 x 10 mm² Min. cross-section 40 x 5 mm² Rated torque 56Nm |
| smart ARS 2-6-2V PRO | Fuse-switch-disconnector for busbar system 185 mm mounting, 3 pole operated <ul style="list-style-type: none"> ▪ double V-shape terminals (outgoing): Max. cross-section 2 x 240 mm² Min. cross-section 50 mm² Rated torque 30 Nm ▪ screw terminals M12 (busbars): Max. cross-section 100 x 10 mm² Min. cross-section 40 x 5 mm² Rated torque 56Nm |

Type tests performed with following clamps:

| 35-300 SW-B (Al-clamps) | 2/35-300 SW-B (Al-clamps) |
|---|--|
|  |  |

Copy of marking plate:



| | | |
|--|--|---|
| <p>  APATOR  </p> <p> Typ <i>smart</i> ARS 2-6-M PRO PV Nr 63-073822-003 Un=800V~ </p> <p>  </p> <p> AC-21B/800V/200A In=Ie=200A NH 1 NH 2 Pn=21W 50-60Hz IP 30 </p> <p>PN-EN 60947-3</p> <p style="writing-mode: vertical-rl; transform: rotate(180deg);">Odstaszewo 57C, 87-148 Łysomice</p> | <p>  APATOR  </p> <p> Typ <i>smart</i> ARS 2-6-V PRO-PV Nr 63-073822-001 Un=800V~ </p> <p>  </p> <p> AC-21B/800V/200A In=Ie=200A NH 1 NH 2 Pn=21W 50-60Hz IP 30 </p> <p>PN-EN 60947-3</p> <p style="writing-mode: vertical-rl; transform: rotate(180deg);">Odstaszewo 57C, 87-148 Łysomice</p> | <p>  APATOR  </p> <p> Typ <i>smart</i> ARS 2-6-2V PRO-PV Nr 63-073822-005 Un=800V~ </p> <p>  </p> <p> AC-21B/800V/200A In=Ie=200A NH 1 NH 2 Pn=21W 50-60Hz IP 30 </p> <p>PN-EN 60947-3</p> <p style="writing-mode: vertical-rl; transform: rotate(180deg);">Odstaszewo 57C, 87-148 Łysomice</p> |
|--|--|---|

| Test item particulars: | |
|---|--|
| - method of operation | Dependent manual operation |
| - suitability for isolation..... | suitable |
| - degree of protection | Device in normal operating condition, with covers, closed: IP30 |
| - number of poles..... | 3 |
| - kind of current..... | AC |
| -in the case of a.c., number of phases and rated frequency..... | 3, 50-60Hz |
| - number of positions of the main contacts (if more than two)..... | 2 |
| -breaking arrangement for fused devices | --- |
| Rated and limiting values, main circuit: | |
| - rated operational voltage U_e (V)..... | 800 V a.c. |
| - rated insulation voltage U_i (V) | 1000 |
| - rated impulse withstand voltage U_{imp} (kV) | 12 |
| - conventional free air thermal current I_{th} with fuse-links (A) | 200 |
| - conventional free air thermal current I_{th} with solid-links (A)..... | --- |
| - rated operational current I_e (A)..... | 200 |
| - rated uninterrupted current I_u (A) | 200 |
| - rated frequency (Hz)..... | 50-60 |
| - utilization category | AC-21B |
| Short-circuit characteristic: | |
| - rated short-time withstand current I_{cw} (kA).... | --- |
| - rated short-time making capacity I_{cm} (kA).... | --- |
| - rated conditional short-circuit current..... | 10 kA / 800V |
| Control circuits | --- |
| Auxiliary circuits | --- |
| Relays and releases | --- |
| Co-ordination with short-circuit protective devices: | |
| - kind of protective device..... | Fuse-links NH1 (200A)/gS (gRL) |

| | |
|--|---|
| <p>Possible test case verdicts:</p> <p>- test case does not apply to the test object.....: N/A</p> <p>- test object does meet the requirement: P (Pass)</p> <p>- test object does not meet the requirement.....: F (Fail)</p> | |
| <p>Testing</p> <p>Date of receipt of test item: 07/2018</p> <p>Date (s) of performance of tests.....: 07/2018 to 08/2018</p> | |
| | |
| <p>General remarks:</p> <p>"(see Enclosure #)" refers to additional information appended to the report.</p> <p>"(see appended table)" refers to a table appended to the report.</p> <p>Throughout this report a <input checked="" type="checkbox"/> comma / <input type="checkbox"/> point is used as the decimal separator.</p> | |
| <p>Manufacturer's Declaration per sub-clause 6.2.5 of IEC60947-2:</p> | |
| <p>The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided</p> | <p><input type="checkbox"/> Yes</p> <p><input checked="" type="checkbox"/> Not applicable</p> |
| <p>When differences exist; they shall be identified in the General product information section.</p> | |
| <p>Name and address of factory (ies).....: APATOR S.A Centrum Ostaszewo 57 C 87-148 Lysomice, POLAND</p> | |
| <p>General product information:</p> <p style="text-align: center;">Low-voltage fuse-switch-disconnectors (for use with NH1 and NH2 fuse-links)</p> <p style="text-align: center;">type</p> <p style="text-align: center;">smart ARS 2-6-. PRO-PV (three pole operated)</p> | |

Remark to test performance:

At all tests concerning making and breaking capacity, operational performance capability and performance under short-circuit conditions, a metallic screen were placed to the equipment, in accordance with the arrangements and distances specified by the manufacturer:

- Distance above to metallic screen: 50mm
- Distance lateral to metallic screen: 30mm

Critical tests such as making and breaking capacity and performance under short-circuit conditions were performed as well as outgoing below and outgoing above.

Remark for use of the fuse-switch-disconnectors:

The maximum power dissipation of the fuse-links suitable for use with the fuse-switch-disconnectors is 21W. Fuse-links with rated voltage 800V of the appropriate size (NH2) may have a power dissipation exceeding this value.

It has to be taken into consideration that the maximum power dissipation of

21W

will not be exceeded for use in uninterrupted duty.